

Bid: 2023-06 Roof Replacement

Posting Date: 3/13/2023

Addendum # 1 Posting Date: 4/06/2023.

Closing Date: 4/18/2023

The information contained in this document shall become an official part of the original document and shall be acknowledged as noted on the Checklist for Bid Documents in the space provided. Failure to acknowledge receipt of an addendum may result in a status of non-responsiveness. Firms are encouraged to review the contents of this document and to respond accordingly.

Addendum #1: The purpose of this document is to provide answers to vendor questions. Please see Questions and Answers included herein.

1. Is there decking and is it be removed, or can new decking be laid on top of existing decking? What type of decking?
There is no decking currently.
OSB ½ inch decking base bid.
2. Are dumpsters allowed in grassy areas?
Dumpsters on concrete areas. May put trailers on grass areas if boards and plastic are placed down first to protect the landscape.
3. What color of shingles?
Shingle color - Natural Cedar Shake.
(F-Wave Hand Split Shake Synthetic Shingles)
4. Pricing for Facia /Trim/Molding?

Crown Molding – Linear foot price
Board foot price for all other wood
5. Are we to install drip edge along the roof?
Yes.
6. Is there a specific manufacturer regarding the shake shingles we are required to use?
No.
7. Is there a bid bond required?
Yes.